

Inspecta Latvia has granted this certificate as proof that

**Double leaf fire resisting doors made of „Stålprofil” steel profile system SP 76500**

**with maximum dimensions 1065 mm x 2265 mm and  
with maximum dimensions of glazing in door leaf 925 mm x 2135 mm**

PRODUCED BY THE MANUFACTURER:

**SIA "ZIZ"**

ADDRESS:

Kandavas iela 41A, Rīga, LV-1083, Latvia; Reg. No. 40103652148

ADDRESS OF MANUFACTURER:

SIA "ZIZ", Kandavas iela 41A, Rīga, LV-1083, Latvia

CERTIFIED ACCORDING:

Testing results according to standard LVS EN 13501-2 („Exova Warringtonfire” Classification of fire resistance No. 308831F (14.07.2011.))

**LVS EN 13501-2+A1:2010**

**„Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services”: fire resistance class E60-C0/EW60-C0/EI130-C0/EI230-C0**

CERTIFICATE ISSUED ON: 24.11.2014.

  
**Martins Maskavs**  
Certification Manager

Certificate was first issued on 24<sup>th</sup> November 2014 and remains valid as long as the conditions set down in the certificate mentioned standard, related provisions and the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Certificate is issued on 1 (one) page

